



ELECTRIC WATER HEATER SCHEDULE										
MARK	TYPE	LOCATION	STORAGE CAPACITY	ELECTRICAL			EXPANSION TANK		MOUNTING	REMARKS
				KILOWATTS	VOLTS	PHASE	ACCEPTANCE	TOTAL		
WH-1	STORAGE	ROOM 155	120	4.5	208	1	1.14	2.71	FLOOR	INSTALL PER MANUFACTURER'S RECOMMENDATION
WH-2	STORAGE	ROOM 106A	40	4.5	208	1	.38	.90	FLOOR	INSTALL PER MANUFACTURER'S RECOMMENDATION
WH-3	STORAGE	KITCHENETTE/REMOTE SINK	6	3	120	1	.08	.18	SHELF	INSTALL IN CABINET


PUMP SCHEDULE										
MARK	TYPE	MANUFACTURER	MODEL	LOCATION	GPM	VOLTAGE	HP	PHASE	HEAD	REMARKS
RP-1	RECIRC DHW	BELL & GOSSETT	PR SERIES	ROOM 155	5	120	1/6	1	12'	INSTALL PER MANUFACTURER INSTRUCTIONS



↑ GLENN'S CAMPUS PLUMBING ENLARGED PLAN 1  
SCALE: 1/4" = 1'-0"




↑ GLENN'S CAMPUS PLUMBING ENLARGED PLAN 2  
SCALE: 1/4" = 1'-0"



↑ GLENN'S CAMPUS PLUMBING ENLARGED PLAN 3  
SCALE: 1/4" = 1'-0"

NOTES THIS SHEET


- 1 6 GALLON ELECTRIC WATER HEATER LOCATED IN CABINET.
- 2 2" HUB DRAIN FOR WATER HEATER PAN.



ELECTRIC WATER HEATER DETAIL (WH-1)

NO SCALE  
NOTE: REFER TO RISER DIAGRAMS FOR PIPE SIZES.


4  
P1.7G/P1.7G



ELECTRIC WATER HEATER DETAIL (WH-2)

NO SCALE

5  
P1.7G/P1.7G



ELECTRIC WATER HEATER DETAIL IN CABINET (WH-3)

NO TO SCALE

6  
P1.7G/P1.7G

GRAPHIC SCALES

